

OPERATING INSTRUCTIONS



Translation of the original instructions

HIPACE 1800

Turbopump



Table of contents

1 About this manual				
	1.1	Validity.		4
		1.1.1	Applicable documents	4
	1.2	Conven	tions	4
			Safety instructions	
			Pictographs	
			Instructions in the text	
			Abbreviations	
_			Symbols used	
2		-		
	2.1		precautions	
	2.2		ve equipment	
	2.3		use	
	2.4	Imprope	er use	8
3	Tran	sport ar	nd storage	9
	3.1	Transpo	ort	9
	3.2	Storage		9
4	Prod	luct des	cription	0
	4.1		identification	
			Pump types	
			Pump features	
		4.1.3	Variants	0
			Scope of delivery	
	4.2		n 1	
			Cooling	
			Rotor bearing	
	4.0		Drive	
_	4.3	_	of application	
5				
	5.1		atory work	
	5.2	•		
			Earthquake safety	
			Use of a splinter shield or protection screen	
	5.3		Vibration damper	
	5.5		ng orientation	
	5.4		ting the high vacuum side	
	5.4		Installation of ISO-K flange with ISO-K flange	
			Installation of ISO-K flange with ISO-F flange	
			Installation of ISO-F with ISO-F flange	
	5.5		p the operating fluid	
			HiPace 1800 standard and "C" versions	
		5.5.2	HiPace 1800 "U" and "UC" versions 2	0
	5.6 Connecting the fore-vacuum side			
	5.7	Connec	tions to the turbopump	2
			Electronic drive unit	
			Earthing	
			Electrical connection	
			Remote plug	
	5.8		ory connection	
			Sealing gas connection	
		J.O.Z	venimu valve	4

		5.8.3 Water cooling
6	Ope	ration
	6.1	Commissioning
		6.1.1 Connecting to the mains power supply
	6.2	Operation modes
	6.3	Function description
		6.3.1 Operation without operating unit
		6.3.2 Operation via "remote" connection
		6.3.3 Operation with DCU or HPU
	C 4	6.3.4 Operation via fieldbus
	6.4	Monitoring of the operation conditions
		6.4.1 Operation display via LED
	6.5	Switching off and venting
	0.5	6.5.1 Switching off
		6.5.2 Venting
7	Mair	ntenance / replacement
-	7.1	Maintenance intervals and responsibilities
	7.2	Changing the operating fluid
		7.2.1 Draining the operating fluid
		7.2.2 Filling up the operating fluid
	7.3	Replacing the electronic drive unit
		7.3.1 Rotation speed set value
8	Dec	ommissioning
	8.1	Shutting down for longer periods
	8.2	Re-starting
	8.3	Disposal
9	Malf	functions 36
	9.1	Rectifying malfunctions
10	Serv	vice
11	Spai	re parts HiPace 1800
12	-	essories
13		nnical data and dimensions
		General
		HiPace 1800 / HiPace 1800 U
		HiPace 1800 C / HiPace 1800 U C
		Dimensions
		laration of conformity

1 About this manual

1.1 Validity

This operating manual is for customers of Pfeiffer Vacuum. It describes the functioning of the designated product and provides the most important information for safe use of the unit. The description follows applicable EU guidelines. All information provided in this operating manual refers to the current state of the product's development. The documentation remains valid as long as the customer does not make any changes to the product.

Up-to-date operating instructions can also be downloaded from www.pfeiffer-vacuum.com.

1.1.1 Applicable documents

HiPace 1800, depending on the model	Operating instructions
Operating instructions "Electronic drive unit TC 1200", standard	PT 0239 BN*
Operating instructions "Electronic drive unit TC 1200 PB", Profibus	PT 0269 BN*
Operating instructions "Electronic drive unit TC 1200 E74", acc. Semi E74	PT 0303 BN*
Operating instructions "Electronic drive unit TC 1200 DN", DeviceNet	PT 0353 BN*
Operating instructions "Electronic drive unit TC 1200 EC", EtherCAT	PT 0455 BN*
Declaration of conformity	Part of this document

^{*}also available via www.pfeiffer-vacuum.com

1.2 Conventions

1.2.1 Safety instructions

The safety instructions in Pfeiffer Vacuum operating instructions are the result of risk evaluations and hazard analyses and are oriented on international certification standards as specified by UL, CSA, ANSI Z-535, SEMI S1, ISO 3864 and DIN 4844. In this document, the following hazard levels and information are considered:

DANGER

Imminent danger

Indicates an imminent hazardous situation that will result in death or serious injury.

WARNING

Possibly imminent danger

Indicates an imminent hazardous situation that can result in death or serious injury.

CAUTION

Possibly imminent danger

Indicates an imminent hazardous situation that can result in minor or moderate injury.

NOTICE

Command or note

Command to perform an action or information about properties, the disregarding of which may result in damage to the product.

1.2.2 Pictographs



Prohibition of an action to avoid any risk of accidents, the disregarding of which may result in serious accidents



Warning of a displayed source of danger in connection with operation of the unit or equipment



Command to perform an action or task associated with a source of danger, the disregarding of which may result in serious accidents



Important information about the product or this document

1.2.3 Instructions in the text

→ Work instruction: here you have to do something.

1.2.4 Abbreviations

DCU: Display Control Unit

HPU: Handheld Programming Unit

TC: Electronic drive unit for turbopump

PB: Profibus version

DN: DeviceNet version

1.2.5 Symbols used

The following symbols are used consistently throughout the diagrams:

- High vacuum flange
- Fore-vacuum flange
- Vacuum flange of the backing pump
- Exhaust flange of the backing pump
- Electrical connection
- Sealing gas connection
- Venting connection

2 Safety

2.1 Safety precautions



Duty to inform

Each person involved in the installation, operation or maintenance of the vacuum pump must read and observe the safety-related parts of these operating instructions.

→ The operator is obligated to make operating personnel aware of dangers originating from the vacuum pump, the pumped medium and the entire system.



Installation and operation of accessories

Pfeiffer Vacuum pumps can be equipped with a series of adapted accessories. The installation, operation and maintenance of connected devices are described in detail in the operating instructions of the individual components.

- → For information on order numbers of components, see "Accessories".
- → Use original accessory parts only.



NOTICE

Checking the safety system against excess rotation speed

To provide the functioning of the integrated safety system for avoiding excess rotation speed, the pump must run-up from the standstill at least once a year.

- → Switch off the pump and await the complete standstill (rotation speed = 0 Hz).
- → Run-up the pump according to this operating instructions.



WARNING

Danger of unsafe electrical installation

Safe operation after installation is the responsibility of the operator.

- → Do not independently modify or change the pump and electrical equipment.
- → Make sure that the system is integrated in an emergency off safety circuit.
- → Consult Pfeiffer Vacuum for special requirements.



WARNING

Danger due to lack of power disconnection device

Pump and electronic drive unit are not equipped with a power disconnection device. Installation of a user-supplied power disconnection device in accordance with SEMI-S2.

→ Fit a circuit breaker with an interruption rating of min. 10,000 A.



WARNING

Danger of electric shock

In case of defect, the parts connected to the mains supply are under voltage.

- → Always keep the mains connection freely accessible so that you can disconnect it at any time.
- Do not expose any body parts to the vacuum.
- Observe all safety and accident prevention regulations.
- Regularly check the proper observance of all safety measures.
- Always ensure a safe connection to the protective earthing conductor (PE, protection class I).
- Do not loosen any plug connection during operations.
- Wait for the rotor to reach standstill before peforming work on the high vacuum flange.
- Keep leads and cables well away from hot surfaces (> 70 °C).
- Never fill or operate turbopump with cleaning agent.
- Do not operate the turbopump with open high vacuum flange.

- Do not carry out any unauthorized modifications or conversions to the pump.
- When returning the turbopump observe the shipping instructions.


2.2 Protective equipment

Determined situations concerning the handling of vacuum pumps require wearing of personal protective equipment. The owner, respectively the employer are obligated to provide an adequate equipment to any operating persons.



DANGER


Danger to health by hazardous substances during maintenance or installation
Depending on the process vacuum pumps, components or operating fluids can be contaminated by toxic, reactive or radioactive substances.






WARNING

Risk of injury through falling objects





- → Carry vacuum pumps > 20 kg by a suitable lifting device.
- → Wear safety shoes with steel toe cap according to directive EN 347.



CAUTION

Risk of injury through hot surfaces

Vacuum pumps can become hot during operation.



- → Allow the pump to cool before maintenance and repairs.
- → If necessary wear protective gloves according to EN 420.



CAUTION

Risk of injury through sharp edges

Rotor and stator disks of turbopumps have very sharp edges.



- → Before any working wait for the complete standstill of the pump.
- → Do not reach in the high vacuum flange.
- → If necessary wear protective gloves according to EN 420.

2.3 Proper use



NOTICE

EC conformity

The manufacturer's declaration of conformity becomes invalid if the operator modifies the original product or installs additional components.

- → Following installation into a plant and before commissioning, the operator must check the entire system for compliance with the valid EU directives and reassess it accordingly.
- The vacuum pump may only be used to generate a vacuum.
- Only operate the turbopump with an approved backing pump.

2.4 Improper use

Improper use will cause all claims for liability and warranties to be forfeited. Improper use is defined as usage for purposes deviating from those mentioned above, especially:

- transport, installation or operation of the pump in invalid orientation
- installation of the pump with unspecified mounting material
- pumping of corrosive gases (exception: pumps in C version)
- pumping of corrosive gases without sealing gas (only pumps in C version)
- · pumping of explosive media
- pumping of condensing vapors
- operation with improper high gas throughput
- operation with improper high fore-vacuum pressures
- · operation with improper gas mode
- · operation with improper high levels of insulated heat input
- venting with improper high venting rates
- operation of the devices in areas with ionizing radiation
- operation in potentially explosive areas
- use of the devices in systems in which impact-like stress and vibrations or periodic forces affect the devices
- use of accessories or spare parts, which are not named in this manual
- fixing the pump at its bottom part



Closure seal

The product is sealed at the factory. Damaging or removal of a closure seal leads to the loss of liability and warranty entitlements.

- → Do not open the product within its warranty period!
- → For process-related shorter maintenance intervals please contact the Pfeiffer Vacuum Service.

3 Transport and storage

3.1 Transport

Two pieces of eye bolts are srewed with the pump on delivery.



NOTICE

Observe type-specific mounting orientations!

Incorrect mounting orientations result in contamination of the process vacuum or damage to the pump.

- → Pay attention to the properties after the model designation on the name plate!
- → Observe the pictographs on the pump housing!
- → Do not transport or tilt the pump filled with operating fluid!





Fig. 1: Transport of HiPace 1800

Fig. 2: Transport of HiPace 1800 U



WARNING

Danger from falling and swinging loads!

When lifting the pump there is a danger of falling parts.

- → Make sure that there are no persons under the suspended load.
- → Close off and supervise the area under the pump.
- → Only transport the turbopump in the valid orientation and with vertical rotor axis.
- → Fix a suitable lifting device on both eye bolts.
 - Observe the approved fixing (e.g. maximum opening angle towards the longitudinal axis of the pump).
 - Do not lift any additional weights (e.g. vacuum chamber).
- → Lift the pump perpendicularly out of the packing.
- → Reuse the transport container of the vacuum pump.
 - Transport or ship vacuum pumps in the original packing preferably.
- → Only remove the protective covers from the high vacuum and the fore-vacuum side immediately before connection.
- → Keep the original protective covers.
- → After the transport the eye bolts can be removed.

3.2 Storage

- → Close the flange openings by using the original protective covers.
- → Close further connection ports by using the corresponding protective covers.
- → Store the pump only indoors at temperatures between -25 °C and +55 °C.
- → In rooms with moist or aggressive atmospheres, the pump must be airproof shrink-wrapped in a plastic bag together with a bag of desiccant.

4 Product description

4.1 Product identification

4.1.1 Pump types

The product designation consists of a family designation (1), the size (2), which is oriented on the pumping speed, and if applicable the additional properties (3) of the pump.

HiPace⁽¹⁾ 1800⁽²⁾U C⁽³⁾

1. Family designation	2. Model designation	3. Property designation
HiPace	ing speed class	
		U = Upside-down installation orientation
		C = Corrosive gas version
		P = Process
		M = Active magnetic bearing
		T = Temperature management system
		E = High Efficiency
		H = High Compression
		I = Ion implantation

4.1.2 Pump features



This product has been tested to the requirements of CAN/CSA-C22.2 No. 61010-1, second edition, including Amendment 1, or a later version of the same standard incorporating the same level of testing requirements.

For information about other certifications, if applicable, please see the signet on the product or:

- www.tuvdotcom.com
- TUVdotCOM-ID 0000021320

Characteristics	HiPace 1800		
HV flange	DN 200 ISO-K	DN 200 ISO-F	
Flange material	Aluminium	Aluminium	

To correctly identify the product when communicating with Pfeiffer Vacuum, always have the information from the rating plate available.



Fig. 3: Example for a rating plate

4.1.3 Variants


- HiPace 1800
- HiPace 1800 C, corrosive gas version
- HiPace 1800 U, for upside-down installation orientation
- HiPace 1800 U C, for upside-down installation orientation and corrosive gases

4.1.4 Scope of delivery

- Turbopump with electronic drive unit and integrated power supply
- Protective cover for the high vacuum flange and the fore-vacuum flange
- Mating plug for the connection "remote" on the TC 1200 (type dependent)
- Mating plug for the connection "E74" on the TC 1200 (type dependent)
- HAN3A socket for mains power supply
- · Sealing gas valve
- Operating fluid (50 ml) with filling syringe
- Screw-in nozzle (2x) with seal ring for cooling water connection
- Eve bolts
- Operating instructions

4.2 **Function**

The turbopumps HiPace 1800 form a complete unit together with the electronic drive unit. The voltage is supplied via the integrated power supply pack.



HiPace 1800 with TC 1200, standard and "U" version Fig. 4:

- Electronic drive unit TC 1200
- 2 Rating plate
- 3 Earthing connection
- High vacuum flange
- Cooling water connection
- Fore vacuum connection
- Sealing gas connection
- 8 Operating fluid pump
- Mains connection "ACin"
- 10 Vent connection

4.2.1 Cooling

Water cooling

In the case of excess temperature the electronic drive unit reduces the drive power automatically.

4.2.2 Rotor bearing

Hybrid bearing turbopump

- High vacuum side: maintenance-free permanent magnetic bearing
- Fore-vacuum side: ceramic ball bearing

4.2.3 Drive

Electronic drive unit TC 1200

4.3 Range of application

The pump HiPace 1800 must be installed and operated under the following ambient conditions:

Installation location	weather protected (indoors)
Protection class	IP 54
Temperature	+5 °C to +40 °C
Relative humidity	max. 80 %, at T \leq 31 °C, to max. 50 % at T \leq 40 °C
Atmospheric pressure	750 hPa - 1060 hPa
Installation altitude	2000 m max.
Degree of pollution	2
Permissible surrounding magnetic field	≤ 7 mT
Overvoltage category	II
Connection voltage	100-120/200-240 (± 10%) V AC



Remarks to ambient conditions

The specified permissible ambient temperatures apply to operation of the turbopump at maximum permissible fore-vacuum pressure or at maximum gas throughput depending on the cooling method. The turbopump is intrinsically safe by a redundant temperature monitoring.

- By reducing the fore-vacuum pressure or gas throughput, the turbopump can be operated at higher ambient temperatures.
- If the maximum permissible operating temperature of the turbopump is exceeded, the electronic drive unit reduces drive power first and switches off then, if necessary.

5 Installation



WARNING

Danger from the turbopump being ripped off

If the rotor is suddenly blocked, torques of up to 16000 Nm could occur, which could cause the turbopump to be ripped off if it is not properly affixed. The energy that this would release could throw the entire pump or pieces from its interior through the room. That would cause severe, possibly fatal, injuries as well as serious property damage.

- → Carefully follow the installation instructions in this handbook.
- → Only use approved original parts from Pfeiffer Vacuum (Accessories) for the installation.



NOTICE

Danger of destroying the pump through impermissible gas loads

An inadmissibly high pressure increase in the pump during operation can result in the destruction of the rotor and the entire pump.

- → Protect the high-vacuum side and fore-vacuum side against impermissible gas seepage.
- → Protect the fore-vacuum lines against external mechanical influences.
- → Protect the isolation devices on the high-vacuum side against accidental opening.
- → Observe the permitted venting rates (max. 15 hPa/s).



Installation and operation of accessories

Pfeiffer Vacuum pumps can be equipped with a series of adapted accessories. The installation, operation and maintenance of connected devices are described in detail in the operating instructions of the individual components.

- → For information on order numbers of components, see "Accessories".
- → Use original accessory parts only.



Operating fluid filling

The pump is delivered without operating fluid filling. The operating fluid is part of the delivery consignment.

→ Do not fill the pump with operating fluid until the installation is done on site!

5.1 Preparatory work

When installing the pump, observe the following conditions:

- the ambient conditions specified for the range of application
- The attachment of the pump at its bottom part is not permitted.
- It is not allowed to operate the device in systems where impact-like stresses and vibrations or periodically forces occur.
- → Ensure sufficient cooling for the turbopump.
- → Where magnetic fields > 7 mT are involved, a suitable shielding must be used. Check installation location and consult Pfeiffer Vacuum if needed!
- → The maximum permissible rotor temperature for the turbopump is 120 °C. If high temperatures arise for process reasons, the radiated heat input must not exceed 24 W. Install suitable screening sheets, if necessary (design information on request).

5.2 Set-up

- Ensure the greatest possible cleanliness when installing any high vacuum parts. Unclean components prolong the pump-down time.
- All flange components must be grease-free, dust-free and dry at installation.

5.2.1 Earthquake safety

An earthquake can result in contact with the safety bearings. All forces occurring hereby are safely absorbed by the properly installed flange connections.

→ Secure the vacuum chamber against shifting and tipping on customers side.




Fig. 5: Example: How to secure against shifting and tipping by external tremors

= Safety connection, implementation each by the customer

5.2.2 Use of a splinter shield or protection screen

Pfeiffer Vacuum centering rings with splinter shield or protection screen in the high vacuum flange protect the turbopump against foreign bodies coming from the chamber. Thus, the pumping speed of the pump is reduced.

	Volume flow rate reduction in %			
	H ₂	Не	N ₂	Ar
Splinter shield DN 200	10	13	26	28
Protection screen DN 200	3	3	8	9

5.2.3 Vibration damper



WARNING

Danger from the turbopump and vibration damper being torn-off

In case of sudden blocking of the rotor, an applied vibration damper cannot compensate any of the occurring forces. There is a danger of the turbopump being torn-off and thereby resulting severest injuries and property damages. Applicable safeguards must be taken to compensate possible occurring torques.

- → Definitely consult with Pfeiffer Vacuum.
- → Do not exceed the max. permissible temperature at the vibration damper (100 °C).

5.3 Mounting orientation



NOTICE

Observe type-specific mounting orientations!

Incorrect mounting orientations result in contamination of the process vacuum or damage to the pump.

- → Pay attention to the properties after the model designation on the name plate!
- → Observe the pictographs on the pump housing!
- → Do not transport or tilt the pump filled with operating fluid!




Fig. 6: Standard and C-versions


Fig. 7: U- and U C-versions

Simple recognition of the valid mounting orientation

The valid mounting orientation of a turbopump can be deduced by the orientation of its operating fluid pump:

- Horizontal longitudinal axis of the operating fluid pump
- Vertical longitudinal axis with the sight glass pointing downwards.

5.3.1 Horizontal mounting orientation



- → For horizontal installation, the fore-vacuum flange must point vertically downward (± 25°), since otherwise the turbopump can be contaminated.
- → Support pipes in front of the vacuum pump or remove them. No force from the pipe system may be exerted on the fixed pump.

The maximum axial loading capacity of the high vacuum flange is 2000 N (equals 200 kg). A one-sided load on the high vacuum flange is not permitted.

5.4 Connecting the high vacuum side

If the rotor is suddenly blocked, the torques arising from the system and the high vacuum flange must be absorbed. Only the components listed in the following can be used to fasten the turbopumps to the high vacuum flange. The installation elements for turbopumps are special designs by Pfeiffer Vacuum. In all operating conditions, the tensile strength of the flange material must be at least 170 N/mm².

→ Secure the vacuum chamber against shifting and tipping on customers side.



DANGER

Danger to life - impermissible fastening

Twisting or tearing-off is possible in case the rotor is suddenly blocked due to the fastening of pumps on a vacuum chamber with different flange variants.

- → Use only the correct mounting kit from Pfeiffer Vacuum.
- → Pfeiffer Vacuum will not accept any liability for all damages resulting from impermissible fastening.



DANGER

Life-threatening hazard - incorrect mounting

The use of clamps to mount pumps can result in life-threatening situations if the rotor suddenly blocks.

- → Never use claws to mount the pumps!
- → Use only the correct mounting kit from Pfeiffer Vacuum.



NOTICE

Observe shape tolerances for the counter flange

Unevennesses of the customer supplied counter flange can lead to warping of the pump casing despite proper fastening. Leakiness and negative running characteristics can be the result.

→ Do not exceed an evenness of max. 0.05 mm for the whole surface.



Mounting of ISO flanges

If the rotor suddenly blocks the connection of high vacuum flanges of types ISO-KF or ISO-K can lead to twisting despite proper installation.

The tightness of the high vacuum flange is not at risk thereby.

5.4.1 Installation of ISO-K flange with ISO-K flange

For the installation the following components are exclusively authorized:

- the valid mounting kit of the Pfeiffer Vacuum accessories programme
- mounting materials including protection screen or splinter shield are optionally available



- → Mind that the sealing surfaces are not damaged.
- 1) Connect the flanges according to the drawing and with the component parts of the mounting kit.
- 2) Use the required number of 24 claw clamps.
- 3) Tighten the claw clamps crosswise in three steps.
- 4) Tightening torque: 5, 15, 25 ±2 Nm

5.4.2 Installation of ISO-K flange with ISO-F flange

The connection types for installation of ISO-K to ISO-F flange are "hex screw and threaded hole," "stud screw and threaded hole," and "stud screw and through hole".

For the installation the following components are exclusively authorized:

- the valid mounting kit of the Pfeiffer Vacuum accessories programme
- mounting materials including protection screen or splinter shield are optionally available

Hexagon screw and threaded hole


- → Mind that the sealing surfaces are not damaged.
- 1) Put the collar flange over the high vacuum flange of the turbopump.
- 2) Insert the retaining ring into the groove of the high vacuum flange.
- 3) Fasten the turbo pump with collar flange and centering ring to the counter flange as shown in the graphic.
- 4) Use the required number of 12 hex screws with washer.
- 5) Screw hex screws 1.5 x d into the threaded holes.
 - The tensile strength of the flange material must be at least 270 N/mm² in all operating conditions.
- 6) Tighten the hex screws crosswise in three steps.
- 7) Tightening torque DN 200: 5, 15, 25 ± 2 Nm


Stud screw and threaded hole


- → Mind that the sealing surfaces are not damaged.
- 1) Use the required number of 12 stud screws and nuts.
- 2) Screw in the stud screws with the shorter threaded end 2.5 x d in the bore holes on the counter flange.
- 3) Put the collar flange over the high vacuum flange of the turbopump.
- 4) Insert the retaining ring into the groove of the high vacuum flange.
- 5) Fasten the turbo pump with collar flange and centering ring to the counter flange as shown in the graphic.
- 6) Tighten the nuts crosswise in three steps.
- 7) Tightening torque DN 200: 5, 15, 25 \pm 2 Nm

Stud screw and through hole

- → Mind that the sealing surfaces are not damaged.
- 1) Put the collar flange over the high vacuum flange of the turbopump.
- 2) Insert the retaining ring into the groove of the high vacuum flange.
- 3) Fasten the turbo pump with collar flange and centering ring to the counter flange as shown in the graphic.
- 4) Use the required number of 12 stud screws and nuts.
- 5) Tighten the nuts crosswise in three steps.
- 6) Tightening torque DN 200: 5, 15, 25 ± 2 Nm








5.4.3 Installation of ISO-F with ISO-F flange

The connection types for installation of ISO-F to ISO-F flange are "hex screw and threaded hole," "stud screw and threaded hole," and "stud screw and through hole".

For the installation the following components are exclusively authorized:

- the valid mounting kit of the Pfeiffer Vacuum accessories programme
- mounting materials including protection screen or splinter shield are optionally available




- → Mind that the sealing surfaces are not damaged.
- 1) Connect the flanges according to the drawing and with the component parts of the mounting kit.
- 2) Use the required number of 12 hex screws with washer.
- 3) Screw hex screws 1.5 x d into the threaded holes.
 - The tensile strength of the flange material must be at least 270 N/mm² in all operating conditions.
- 4) Tighten the hex screws crosswise in three steps.
- 5) Tightening torque DN 200: 10, 20, 38 ± 3 Nm

Stud screw and threaded hole


- → Mind that the sealing surfaces are not damaged.
- 1) Use the required number of **12** stud screws and nuts.
- 2) Screw in the stud screws with the shorter threaded end 2.5 x d in the bore holes on the counter flange.
- 3) Connect the flanges according to the drawing and with the component parts of the mounting kit.
- 4) Tighten the nuts crosswise in three steps.
- 5) Tightening torque DN 200: 10, 20, 38 ± 3 Nm

Stud screw and through hole

- → Mind that the sealing surfaces are not damaged.
- Connect the flanges according to the drawing and with the component parts of the mounting kit.
- 2) Use the required number of 12 stud screws and nuts.
- 3) Tighten the nuts crosswise in three steps.
- 4) Tightening torque DN 200: 10, 20, 38 ± 3 Nm



5xd



5.5 Filling up the operating fluid



WARNING

Toxic vapours!

Danger of poisoning when igniting and heating synthetic operating fluids (e.g. F3) above 300 °C.

- → Observe the application instructions.
- → Do not allow operating fluid to make contact with tobacco products; observe safety precautions when handling chemicals.



NOTICE

Destruction of the pump by insufficient operating fluid supply

Missing or insufficient operating fluid supply can lead to the destruction of the turbopump. The position of the filling screws and the filling capacity of operating fluid depends on the orientation of the mounted turbopump.

- → Before starting up for the first time or after each transport: Fill the pump with the adequate amount of operating fluid.
- → Only fill in the operating fluid, after the turbopump is mounted.
- → For type of the operating fluid please refer to the rating plate.
- → Do not mix the filler screws with draining screws! Filler screws are designated with an oilcan-symbol.
- → The operating fluid capacity for a vertically mounted pump is 40 ml.
- → The operating fluid capacity for a horizontally mounted pump must be 50 ml!



Design of the operating fluid pump

The operating fluid pump is largely mirror symmetrical. The screws for filling the operating fluid are located at the sides of the operating fluid pump. The screws for draining the operating fluid are located at the front of the operating fluid pump.

- → Always use the higher positioned screw for filling.
- → Always use the lower positioned screw for draining.
- → Never fill via the draining screws.

5.5.1 HiPace 1800 standard and "C" versions




Fig. 8: Filling the operating fluid at HiPace 1800 standard and "C" versions in their respective valid mounting orientations

- → Turn off the vacuum pump, vent to atmospheric pressure and allow to cool.
- → Unsrew the respectively higher positioned filler screw of the operating fluid pump.
- → Fill in the operating fluid (max. 50 ml) into the operating fluid pump by using the filling syringe.
- → Lock the filler screw again.

5.5.2 HiPace 1800 "U" and "UC" versions




Fig. 9: Filling the operating fluid at HiPace 1800 "U" and "UC" versions in their respective valid mounting orientations

- → Turn off the vacuum pump, vent to atmospheric pressure and allow to cool.
- → Unsrew the respectively higher positioned filler screw of the operating fluid pump.
- → Fill in the operating fluid (max. 50 ml) into the operating fluid pump by using the filling syringe.
- → Lock the filler screw again.

5.6 Connecting the fore-vacuum side

Recommendation: As backing pump, use a suitable vacuum pump from the Pfeiffer Vacuum programme.



WARNING

Damage to health due to poisonous gases

Process gases can damage health and contaminate the environment.

- → Safely lead away the gas emission from the backing pump!
- → Observe all safety recommendations of the gas producer.




Fig. 10: Connecting the backing pump

Fore-vacuum connection 415.1 Centering ring 415.3 Vacuum components 415a Backing pump 415.2 Clamping ring



NOTICE

Design of the fore-vacuum connection regarding sudden twisting of the pump

If the rotor suddenly blocks the connection of high vacuum flanges of types ISO-KF or ISO-K can lead to twisting despite proper installation.

- → Keep masses small, which can be installed directly to the pump.
- → Connect flexible line elements directly to the turbopump, if necessary.
- → With rigid pipe connections: Install bellows for attenuation of vibrations in the connection line.
- → Connect the fore-vacuum line with small-flange components or threaded hose couplings. Do not narrow the free cross section of the fore-vacuum flange!
- → For connection and operation of the backing pump see its operating instructions.

5.7 Connections to the turbopump

5.7.1 Electronic drive unit

Turbopumps with integrated electronic drive unit are designed for various applications. Therefore different connection panels are available.

- TC 1200 in standard version
- TC 1200 PB for Profibus linking
- TC 1200 E74 in dependence on specification SEMI E74
- TC 1200 DN for DeviceNet linking

Detailed description for function, configuration and operation with the respective connection panel are given in the specific operating instructions for the electronic drive unit.

5.7.2 Earthing




Fig. 11: Installing the earthing connection

→ Connect appropriate earthing wire according to local regulations, to derive pplicative interferences.

5.7.3 Electrical connection



WARNING

Danger of unsafe electrical installation

Safe operation after installation is the responsibility of the operator.

- → Do not independently modify or change the pump and electrical equipment.
- → Make sure that the system is integrated in an emergency off safety circuit.
- → Consult Pfeiffer Vacuum for special requirements.



- 1 Phase L
- 2 Neutral conductor
- 3 n.c
- PE Protective earth

Fig. 12: Pin assignment of the mains connection plug

- → Order the mains cable separately (see "accessories").
- → Assemble mains cable for yourself using the supply socket (delivery) if necessary.

5.7.4 Remote plug

The shipment includes a mating plug for the 26-pin connection with the designation "remote" on the TC 1200. The mating plug bridges the following connections with the supply voltage (Pin 1), allowing the turbopump to operate without an additional operating unit or remote control:

- Pin 2, Enable venting "on"
- Pin 3, Motor pump "on"
- Pin 4, Pumping station "on"
- Pin 14, Remote access request
- → Place and fix the mating plug on the connection "remote" on the TC 1200.



CAUTION

Automatic start

After bridging the contacts Pin 1, 3, 4, 14 on the connection "remote" or using the mating plug supplied **and** setting up the supply voltage, the turbopump will run up immediately.

→ Switch on the mains supply on the turbopump immediately before operation.

5.8 Accessory connection

Up to 4 accessories can be connected to the electronic drive unit TC 1200. M12 sockets with the designation "accessory" are available for this purpose. The accessory connections have been preconfigured at the factory. If the units listed below are connected with the preconfigured connection, they are immediately ready for operation according to the factory settings. It is possible to connect other accessories; to do so, settings must be made on the electronic drive unit.



- → To connect two units to one accessory connection, use the appropriate Y-Connector from the Pfeiffer Vacuum range of accessories.
- → Connect the adapter to the appropriate red-coded connection on the TC 1200.
- → Settings can be made via the interfaces of the TC 1200.

Accessory connection	Connection with Y-connector	Preset accessory unit
Accessory A1	Acc. A to Y-1	Sealing gas valve
Accessory A2	Acc. A to Y-2	Backing pump
Accessory B1	Acc. B to Y-1	Venting valve
Accessory B2	Acc. B to Y-2	Casing heating unit

Table 1: Overview of factory preset accessory connections on the TC 1200

5.8.1 Sealing gas connection

The turbopump must be operated with sealing gas to protect it, such as in the case of unclean processes or high gas throughput. The supply is made via a sealing gas valve or alternatively via a sealing gas throttle without control. The activation of the control valve for the sealing gas connection is pre-installed in the electronic drive unit. The sealing gas valve is already part of the delivery consignment.

The permissible connection pressure is max. 1500 hPa absolute.

- When operating the pump with more than 50 % of the maximum gas throughput, sealing gas must be used to ensure rotor cooling.
- The sealing gas flow rate amounts 17.5-20 sccm for the HiPace 1800.

Sealing gas supply with control valve




Fig. 13: Connecting the sealing gas valve

- 1 Seal ring 2 Locking screw
 - 2 Locking screw 3 Sealing gas valve
- → Unscrew the locking screw with seal ring out of the sealing gas connection.
 → Screw the sealing gas valve with seal ring into the sealing gas connection.
- → Insert the control cable of the accessory into a free accessory connector on the TC 1200 and tighten.
- → Make the settings and control via the interfaces of the electronic drive unit.
- → Install the sealing gas supply (e.g. inert gas) via a connection adapter or on the inlet side (G 1/8") of the control valve.

Sealing gas supply without control valve

- → Unscrew the locking screw with seal ring out of the sealing gas connection.
- → Screw the sealing gas throttle with sealing ring into the sealing gas connection.

5.8.2 Venting valve

The Pfeiffer Vacuum venting valve is used for automatic venting in case of shut-down or power failure.

The permissible connection pressure is max. 1500 hPa absolute.

- → Unscrew the venting screw with seal ring from the venting connection.
- → Screw in the venting valve with seal ring.
- → Plug in and fix the accessory's control lead to the corresponding accessory connection port on the electronic drive unit.
- → Default for the venting valve is "accessory B1".
- → If neccessary install a venting gas supply (e.g. inert gas) to the intake (G 1/8") of the solenoid valve.

5.8.3 Water cooling

The turbopumps HiPace 1800 with TC 1200 have water cooling as standard equipment.

Cooling water requirements

Cooling water connection	Hose nozzles G 1/4"		
Hose lines	Internal diameter 7-8 mm with hose clamp		
Cooling water quality	filtrated, mechanically clean, optically clear, no turbidity, no sediments, chemically neutral		
Oxygen content max.	4 mg/kg		
Chloride content max.	100 mg/kg		
Water hardness max.	10 °dH		
	12.53 °e		
	17.8 °fH		
	178 ppm CaC0 ₃		
Consumption of potassium permanganate max.	10 mg/kg		
Carbon dioxide content max.	undetectable		
Ammonia content max.	undetectable		
pH-value	7 - 9		
Fore-line overpressure max.	6000 hPa		
Cooling water temperature	refer to "Technical Data"		
Cooling water consumption at max. gas throughput	refer to "Technical Data"		

Connecting to a cooling water system




Fig. 14: Connecting the cooling water

- Cooling water connection
 Seal ring
 Fore-line
 Screw-in nozzle
 Return-line
- → Connect the cooling water connection alternatively:
 - Direct connection on the pump with G1/4" internal thread.
 - Using screw-in nozzles with seal ring (2 pcs. each in the scope of delivery) for hose internal diameters of 7 - 8 mm.
 - Tightening torque: max. 15 Nm.
- → Recommendation: install dirt trap in the fore-line.
- → Connect the cooling water fore-line to the designated connector.
- → Connect the cooling water return-line to the designated connector.

6 Operation

6.1 Commissioning

The following important settings are programmed in the electronic drive unit ex factory.

- Parameter [P:027] Gas mode: 0 = heavy gases
- Parameter [P:700] Set value max. run-up time monitoring: 8 min
- Parameter [P:701] Rotation speed switchpoint: 80% of the nominal roation speed
- Parameter [P:707] Set value in rotation speed setting mode: 65 % of the nominal rotation speed
- Parameter [P:708] Set value power consumption: 100 %
- Parameter [P:720] Venting rotation speed at delayed venting: 50 % of the nominal rotation speed
- Parameter [P:721] Venting time: 3600 s
- → When water cooling is used: Open cooling water supply and check the flow.
- → When sealing gas is used: Open the sealing gas supply and check the flow.
- → Switch on the pump by connecting the mains cable with the mains supply.



NOTICE

Risk of destroying the pump by inputting too much energy

Simultaneous loading by means of high drive power (gas flow rate, fore-vacuum pressure), high heat radiation, or strong magnetic fields results in uncontrolled heating of the rotor and may destroy the pump.

- → Reduced limit values apply when combining these loads.
- → If necessary consult with Pfeiffer Vacuum.



NOTICE

Danger of the pump being destroyed

Pumping of gases with a higher molecular mass in the wrong gas mode can lead to destruction of the pump.

- → Ensure the gas mode is correctly set.
- → Contact Pfeiffer Vacuum before using gases with a greater molecular mass (> 80).

6.1.1 Connecting to the mains power supply



CAUTION

Automatic start

After bridging the contacts Pin 1, 3, 4, 14 on the connection "remote" or using the mating plug supplied **and** setting up the supply voltage, the turbopump will run up immediately.

→ Switch on the mains supply on the turbopump immediately before operation.



WARNING

Danger of electric shock

In case of defect, the parts connected to the mains supply are under voltage.

- → Always keep the mains connection freely accessible so that you can disconnect it at any time.
- → Insert the mains cable into the mains connection AC in.
- → Lock the mains cable with the mounting bracket.
- → Connect the mains cable to the mains.
- → Always ensure a safe connection to the protective earthing conductor (PE, protection class I).

After the mains voltage is applied, the electronic drive unit performs a self-test to check the supply voltage. The turbopump is set into operation.

Drive power reduction depending on the mains connection voltage

Mains connection voltage	Drive power
100 - 120 V AC	700 - 930 W
200 - 240 V AC	1200 W

The power of the electronic drive unit depends on the provided mains voltage.

6.2 Operation modes

The following operation modes are available:

- Operation without operating unit
- Operation via "remote" connection
- Operation via RS-485 and Pfeiffer Vacuum display and control units or PC
- Operation via field bus

6.3 **Function description**



WARNING

Danger due to open high vacuum flange

The rotor of the turbopump turns at high speed. If the high vacuum flange is open, there is a danger of cut injuries and that the pump can be destroyed by objects falling into it.

→ Never operate the pump with an open high vacuum flange.

6.3.1 Operation without operating unit

→ For operation without the control unit, the 26-pole D-Sub plug must be in the "remote" connection on the TC 1200.

After operating voltage is applied, the TC 1200 performs a self-test to check the supply voltage. Once the self-test has been successfully completed on the TC 1200, the turbopump and the backing pump - if connected - begin to operate.

6.3.2 Operation via "remote" connection

Remote control is possible via the 26-pin D-sub connector labelled "remote" on the electronic drive unit. The accessible individual functions are mapped to "PLC levels".

- → Consider the following manuals for the operation via remote control:
 - Operating instructions "Electronic drive unit TC 1200"

6.3.3 Operation with DCU or HPU

- → Consider the following manuals for the operation via Pfeiffer Vacuum display and control units:
 - Operating instructions "DCU"
 - Operating instructions "HPU"
 - Operating instructions "Electronic drive unit TC 1200"
- → Switch on the pump by connecting the mains cable with the mains supply.
- → Settings are possible via interface RS-485 by using DCU, HPU or PC.

6.3.4 Operation via fieldbus

Integrating and operating Pfeiffer Vacuum turbopumps in the customer's field bus system is possible for electronic drive units with a corresponding field bus panel.

- → Consider the following manuals for the operation via field bus:
 - Operating instructions for the electronic drive unit with the respective connection panel

6.4 Monitoring of the operation conditions

6.4.1 Operation display via LED

LEDs in the front panel of the electronic drive unit show basic operating conditions of the turbopump. A differentiated malfunction and warning display is possible only for operation with DCU or HPU.

LED	Symbol	LED status	Display	Meaning
Green		Off		currentless
		On, flashing		"Pumping Station OFF", rotation speed ≤ 60 min ⁻¹
		On, invers flashing		"Pumping Station ON", set rotation speed not attained
		On, constantly		"Pumping Station ON", set rotation speed attained
		On, blinking		"Pumping Station OFF", rotation speed > 60 min ⁻¹
Yellow		Off		no warning
	Δ	On, constantly		Warning
Red		Off		no malfunction
	4	On, constantly		Malfunction

Fig. 15: Behaviour and meaning of LEDs on the electronic drive unit

6.4.2 Temperature monitoring

The drive power is reduced in case of impermissible motor temperature or impermissibly high housing temperature. This can cause falling below the rotation speed switchpoint and so result in turning off the turbopump.

6.5 Switching off and venting

6.5.1 Switching off

After the turbopump is switched off, it must be vented to avoid contamination due to particles streaming back from the fore-vacuum area.

- → Close the fore-vacuum: Switch off the backing pump or close a fore-vacuum valve.
- → Switch off the turbopump on the control unit or via remote control.
- → Venting (possibilities see below)
- → Leave open the cooling water supply until the halt of the rotor (rotation speed < 1 Hz).

6.5.2 Venting

Manually venting

→ Open the venting screw (included) in the venting connection of the turbopump about one turn.

Venting with Pfeiffer Vacuum Venting Valve

- → Enable venting via the functions of the electronic drive unit.
- → Settings are possible via interface RS-485 by using DCU, HPU or PC.

Venting rotation speed	Switch off the pumping station	Mains power failure ¹⁾	
50 % of the nominal rotation	Venting valve opens for 3600 s (1 h,	Venting valve opens for	
speed	works setting)	3600 s (1 h, works setting)	

¹⁾When mains power is restored the venting procedure is aborted.

Basic information for the rapid venting

Venting of the vacuum chamber in two steps. Ask for details on individual solutions from Pfeiffer Vacuum.

- → Vent for 20 seconds at a rate of pressure rise of max. 15 hPa/s.
 - The valve cross section for the venting rate of 15 hPa/s must be adapted to the size of the vacuum chamber.
 - For small vacuum chambers, use the Pfeiffer Vacuum venting valve.
- → Then vent with an additional venting valve of any desired size.

7 Maintenance / replacement



WARNING

Contamination of parts and operating fluid by pumped media is possible.

Poisoning hazard through contact with materials that damage health.

- → In the case of contamination, carry out appropriate safety precautions in order to prevent danger to health through dangerous substances.
- → Decontaminate affected parts before carrying out maintenance work.



WARNING

Toxic vapours!

Danger of poisoning when igniting and heating synthetic operating fluids (e.g. F3) above 300 °C.

- → Observe the application instructions.
- → Do not allow operating fluid to make contact with tobacco products; observe safety precautions when handling chemicals.



NOTICE

Disclaimer of liability

Pfeiffer Vacuum accepts no liability for personal injury or material damage, losses or operating malfunctions due to improperly performed maintenance. The liability and warranty entitlement expires.

7.1 Maintenance intervals and responsibilities

- Clean the turbopump externally with a lint-free cloth and little industrial alcohol.
- Replace the electronic drive unit yourself.
- Change the operating fluid yourself.
- Change the operating fluid at least every 4 years.
- Change the turbopump bearing at least every 4 years.
 - Contact Pfeiffer Vacuum Service.
- Clarify shorter maintenance intervals for extreme loads or impure processes with Pfeiffer Vacuum Service.
- For all other cleaning, maintenance or repair work, please contact your Pfeiffer Vacuum service location.

7.2 Changing the operating fluid



WARNING

Poisoning hazard through contact with materials that damage health.



Operating fluid and parts of the pump may contain toxic substances from the pumped media.

- → Dispose of operating fluid in accordance with the applicable regulations. Safety data sheet on request or under www.pfeiffer-vacuum.com
- → Prevent health hazards or environmental damage due to contamination by means of appropriate safety precautions.
- → Decontaminate affected parts before carrying out maintenance work.



Design of the operating fluid pump

The operating fluid pump is largely mirror symmetrical. The screws for filling the operating fluid are located at the sides of the operating fluid pump. The screws for draining the operating fluid are located at the front of the operating fluid pump.

- → Always use the higher positioned screw for filling.
- → Always use the lower positioned screw for draining.
- → Never fill via the draining screws.

7.2.1 Draining the operating fluid




Fig. 16: Draining the operating fluid at HiPace 1800 Standard and U-versions in their respectively horizontal mounting orientation

- → Turn off the vacuum pump, vent to atmospheric pressure and allow to cool.
- → Unsrew the respectively lower positioned drain screw of the operating fluid pump.
- → Drain the operating fluid in a suitable tank.
- → Lock the drain screw again.

7.2.2 Filling up the operating fluid



NOTICE

Destruction of the pump by insufficient operating fluid supply

Missing or insufficient operating fluid supply can lead to the destruction of the turbopump. The position of the filling screws and the filling capacity of operating fluid depends on the orientation of the mounted turbopump.

- → Before starting up for the first time or after each transport: Fill the pump with the adequate amount of operating fluid.
- → Only fill in the operating fluid, after the turbopump is mounted.
- → For type of the operating fluid please refer to the rating plate.
- → Do not mix the filler screws with draining screws! Filler screws are designated with an oilcan-symbol.
- → The operating fluid capacity for a vertically mounted pump is 40 ml.
- → The operating fluid capacity for a horizontally mounted pump must be 50 ml!




Fig. 17: Filling the operating fluid at HiPace 1800 standard and "C" versions in their respective valid mounting orientations

- → Turn off the vacuum pump, vent to atmospheric pressure and allow to cool.
- → Unsrew the respectively higher positioned filler screw of the operating fluid pump.
- → Fill in the operating fluid (max. 50 ml) into the operating fluid pump by using the filling syringe.
- → Lock the filler screw again.




Fig. 18: Filling the operating fluid at HiPace 1800 "U" and "UC" versions in their respective valid mounting orientations

- → Turn off the vacuum pump, vent to atmospheric pressure and allow to cool.
- → Unsrew the respectively higher positioned filler screw of the operating fluid pump.
- → Fill in the operating fluid (max. 50 ml) into the operating fluid pump by using the filling syringe.
- → Lock the filler screw again.

7.3 Replacing the electronic drive unit



NOTICE

Observe mounting orientations when replacing the electronic drive unitl

Electronic drive unit replacement can be carried out at the installed pump. When dismounting the pump from the system, observe:

- → Drain pump operating fluid before dismounting from the system.
- → Pay attention to the properties after the model designation on the name plate!
- → Observe the pictographs on the pump housing!
- → Replace the electronic drive unit at the horizontally oriented pump with the fore-vacuum connection pointing downward (± 25°).



NOTICE

Damages to the pump and drive

Even after the mains power is switched off, the subsequently running pump delivers electric power to the electronic drive unit. There is a danger of electric body contact by premature separating the pump from the electronic drive unit.

→ Never separate the electronic drive unit from the pump when the mains power is connected or the rotor is running.



Operating parameters of the electronic drive unit

The factory operating parameters are always preset with replacement shipments.

- → The use of a HPU enables the storing and the reuse of an existing parameter record.
- → Reset any individually changed application parameters.
- → Refer to the manual "Electronic drive unit".
- → Do not exercise any mechanical load on the electronic drive unit.
- → Turn off the vacuum pump, vent to atmospheric pressure and allow to cool.
- → Only separate the pump and the electronic drive unit from each other after disconnecting the supply voltage and the complete standstill of the pump.
- → Remove the vacuum pump from the system, if necessary.






Fig. 19: Disassembly / Assembly of TC 1200

- 1 Allen screw (M4 x 50) 3 Lock washer 5 O-ring (192 x 3) 2 Allen screw (M4 x 12) 4 Electronic drive unit 6 Pump bottom part
- → Unscrew Allen screws (7x) from the electronic drive unit.
 - Observe the lock washer.
- → Pull the electronic drive unit straight off the pump.
 - Observe the plug connection.
 - Observe the O-ring.



- → Fix the O-ring in the groove of the pump bottom part, if necessary. Ensure correct seating!
- → Place carefully the new electronic drive unit to the pump bottom part.

- Observe the boreholes for the screw connection.
- Observe the plug connection.



- → Place one Allen screw together with the lock washer underneath the mains plug.
- → Tighten the electronic drive unit with the Allen head screws.
 - Tightening torque **2.5 Nm**.



NOTICE

Visual inspection - avoid malfunction!

Incorrect assembling of the electronic drive unit may lead to malfunctions!

- → The base plate of the electronic drive unit must be seated planar on the cooling plate of the pump.
- → If necessary loosen and reassemble the electronic drive unit. Observe the O-ring!

7.3.1 Rotation speed set value

The typical nominal rotation speed of a turbopump is factory-set in the electronic drive unit. If the electronic drive unit is replaced or a different pump type is used, the reference set value of the nominal rotation speed must be confirmed. This procedure is part of a redundant safety system for avoiding excess rotation speeds.

HiPace	Nominal rotation speed confirmation [P:777]
1200 / 1500	630 Hz
1800 / 2300	525 Hz

- → Adjust the parameter [P:777] according to the pump type.
- → Alternatively: If no display and control unit is available, please use the "SpeedConfigurator" of the spare parts delivery.

8 Decommissioning

8.1 Shutting down for longer periods



WARNING

Contamination of parts and operating fluid by pumped media is possible.

Poisoning hazard through contact with materials that damage health.

- → In the case of contamination, carry out appropriate safety precautions in order to prevent danger to health through dangerous substances.
- → Decontaminate affected parts before carrying out maintenance work.

If the turbopump should be shut down for longer than a year:

- → Remove the vacuum pump from the system, if necessary.
- → Drain the operating fluid.
- → Close the high vacuum flange of the turbopump.
- → Evacuate turbopump via the fore-vacuum flange.
- → Vent turbopump via the venting connection with oil-free, dry air or inert gas.
- → Close the flange openings by using the original protective covers.
- → Close further connection ports by using the corresponding protective covers.
- → Store the pump only indoors at temperatures between -25 °C and +55 °C.
- → In rooms with moist or aggressive atmospheres, the pump must be airproof shrink-wrapped in a plastic bag together with a bag of desiccant.

8.2 Re-starting



NOTICE

Risk of damage to the pump following recommissioning

The operating fluid in the turbo pump has a limited shelf life. The length of its shelf life is as follows:

- max. 2 years without operation or
- a total of max. 4 years following periods of operation and nonoperation.
- → Follow the maintenance instructions and inform Pfeiffer Vacuum.
- → Check turbopump for contamination and moisture.
- → Clean the turbopump externally with a lint-free cloth and little industrial alcohol.
- → If necessary, have Pfeiffer Vacuum Service clean the turbopump completely.
- → If necessary, have the bearings replaced. Take into account the total running time.
- → Installation and commissioning in accordance with the operating instructions.

8.3 Disposal

Products or parts thereof (mechanical and electrical components, operating fluids, etc.) may cause environmental burden.

→ Safely dispose of the materials according to the locally applicable regulations.

9 Malfunctions

If malfunctions on the pump occur, you will find possible causes and instructions for repair in the following table.

9.1 Rectifying malfunctions

Problem	Possible causes	Remedy
Pump will not start; none of the built-in LEDs on the TC 1200 lights up	Electrical supply interrupted	 ⇒ Check plug contacts on the power supply ⇒ Check supply lines on the power supply
	Operating voltage incorrect	⇒ Apply correct operating voltage⇒ Observe the rating plate
	No operating voltage applied	⇒ Apply operating voltage
	TC 1200 defective	⇒ Request an exchange of the TC 1200 ⇒ Contact the Pfeiffer Vacuum Service
Pump will not start; green LED on the TC 1200 is flashing	At operation without control panel: Pins 1- 3, 1-4 or 1-14 are not connected on the "remote" connection	 Connect the pins 1-3, 1-4 or 1-14 on the "remote" connection Install the mating plug (scope of delivery) to the "remote" connection.
	At operation via RS-485: Bridge at Pin 1- 14 prevents control commands	 ⇒ Remove the bridge at the "remote" connection ⇒ Remove the mating plug from the "remote" connection.
	At operation via RS-485 (without counter plug): Parameters of the electronic drive unit not set	 ⇒ Set parameters [P: 010] and [P: 023] "ON" via interface RS-485. ⇒ Please refer to operating instructions of the electronic drive unit.
Pump does not attain the final rotational speed within the specified run-up time	Fore-vacuum pressure too high	⇒ Ensure function and suitability of the backing pump
	Leak	 ⇒ Perform leak detection ⇒ Check sealings and flange fastenings ⇒ Eliminate leaks
	Gas load too high	⇒ Reduce process gas supply
	Rotor runs hard, bearing defective	⇒ Check the bearing for noises⇒ Contact the Pfeiffer Vacuum Service
	Setpoint for run-up time to low	⇒ Extend the run-up time via DCU, HPU or PC
	Thermal overload: Lack of air ventilation Water flow too low Fore-vacuum pressure too high Ambient temperature too high	Reduce thermal loads Ensure adequate cooling Ensure the cooling water flow Lower the fore-vacuum pressure Adjust ambient conditions
Pump does not attain the ultimate pressure	Pump is dirty	 ⇒ Bake out the pump ⇒ Cleaning in case of heavy contamination Contact the Pfeiffer Vacuum Service
	Vacuum chamber, pipes or pump are leaky	 ⇒ Leak detection starting from the vacuum chamber ⇒ Eliminate leaks
Unusual noises during operation	Bearing damage	⇒ Contact the Pfeiffer Vacuum Service
	Rotor damage	⇒ Contact the Pfeiffer Vacuum Service
	Splinter shield or protective screen are loose	 ⇒ Correct the seat of the splinter shield or the protective screen ⇒ Observe the installation notes
Red LED on the TC 1200 is on	Collective fault	 ⇒ Reset by switching the mains OFF/ON ⇒ Reset via pin 13 on the "REMOTE" connection ⇒ Differentiated malfunction display is possible via "RS 485"¹) ⇒ Contact the Pfeiffer Vacuum Service

¹⁾If no Pfeiffer Vacuum display and control unit is available, please contact the Pfeiffer Vacuum Service.

10 Service

Pfeiffer Vacuum offers first-class service!

- Operating fluid and bearing change on the spot by Pfeiffer Vacuum FieldService
- Maintenance / repair in the nearby ServiceCenter or ServicePoint
- Fast replacement with exchange products in mint condition
- · Advice on the most cost-efficient and quickest solution

Detailed information, addresses and forms at: www.pfeiffer-vacuum.com (Service).

Maintenance and repair in the Pfeiffer Vacuum ServiceCenter

The following steps are necessary to ensure a fast, smooth servicing process:

- → Download the forms "Service Request" and "Declaration on Contamination". 1)
- → Fill out the "Service Request" form and send it by fax or e-mail to your Pfeiffer Vacuum service address.
- → Include the confirmation on the service request from Pfeiffer Vacuum with your ship-
- → Fill out the declaration on contamination and include it in the shipment (required!).
- → Dismantle all accessories.
- → Drain the operating fluid (applies for turbopumps with pumping speed > 700 l/s).
- → Leave electronic drive on the pump.
- → Close the flange openings by using the original protective covers.
- → If possible, send pump or unit in the original packaging.

Sending of contaminated pumps or devices

No units will be accepted if they are contaminated with micro-biological, explosive or radioactive substances. "Hazardous substances" are substances and compounds in accordance with the hazardous goods directive (current version). If pumps are contaminated or the declaration on contamination is missing, Pfeiffer Vacuum performs decontamination at the shipper's expense.

- → Neutralise the pump by flushing it with nitrogen or dry air.
- → Close all openings airtight.
- → Seal the pump or unit in suitable protective film.
- → Return the pump/unit only in a suitable and sturdy transport container and send it in while following applicable transport conditions.

Exchange unit

The factory operating parameters are always preset with exchange units. If you use changed parameters for your application, you have to set these again.


Service orders

All service orders are carried out exclusively according to our repair conditions for vacuum units and components.

¹⁾ Forms under www.pfeiffer-vacuum.com

11 Spare parts HiPace 1800

Item	Designation	Size	Order number	Notes	Pieces	Order
						qty.
1	Electronic drive unit TC 1200		according to the rating plate	depends on the connection panel	1	
2	Mating plug "remote"		PM 061 378 -X	with bridges	1	
3	Mains connection socket	HAN 3	PM 061 200 -T		1	
4	Sealing gas valve	17.5 - 20 sccm	PM Z01 313		1	
5	Syringe	50 ml	PM 006 915 -U		1	
6	Operating fluid F3	50 ml	PM 006 336 -T	other quantities on request	1	
7	Screw-in nozzle	G 1/4"	P 0998 067	for hose internal Ø of 7-8 mm	2	
8	Seal ring		P 3529 145 -A	for screw-in nozzle	2	



Please also specify model number of the the rating plate when ordering accessories or spare parts.

12 Accessories

Designation	DN 200 ISO-K	DN 200 ISO-F
Mounting kit for HiPace 1800, DN 200 ISO-K, including coated centering ring, bracket	PM 016 410 -T	
screws		
Mounting kit for HiPace 1800, DN 200 ISO-K, including coated centering ring, protection screen, bracket screws	PM 016 412 -T	
Mounting kit for HiPace 1800, DN 200 ISO-K, including coated centering ring, splinter shield, bracket screws	PM 016 411 -T	
Mounting kit for DN 200 ISO-K to ISO-F, with collar flange, coated centering ring with splinter shield, hexagon bolts	PM 016 961 -T	
Mounting kit for DN 200 ISO-K to ISO-F, with collar flange, coated centering ring, hexagon bolts	PM 016 960 -T	
Mounting kit for DN 200 ISO-K to ISO-F, with collar flange, coated centering ring with protection screen, hexagon bolts	PM 016 962 -T	
Mounting kit for DN 200 ISO-K to ISO-F, with collar flange, coated centering ring, stud screws	PM 016 965 -T	
Mounting kit for DN 200 ISO-K to ISO-F, with collar flange, coated centering ring with splinter shield, stud screws	PM 016 966 -T	
Mounting kit for DN 200 ISO-K to ISO-F, with collar flange, coated centering ring with protection screen, stud screws	PM 016 967 -T	
Mounting kit for HiPace DN 200 ISO-F, including coated centering ring, hexagon screws		PM 016 470 -T
Mounting kit for DN 200 ISO-F, including coated centering ring, protective screen, nexagon screws		PM 016 472 -T
Mounting kit for DN 200 ISO-F, including coated centering ring, splinter shield, hexagon screws		PM 016 471 -T
Mounting kit for DN 200 ISO-F, including coated centering ring, stud screws		PM 016 475 -T
Mounting kit for DN 200 ISO-F, including coated centering ring, protective screen, studecrews		PM 016 477 -T
Mounting kit for DN 200 ISO-F, including coated centering ring, splinter shield, stud		PM 016 476 -T
Centering ring with multifunction coating, DN 200 ISO-K/-F	PM 016 220 -U	PM 016 220 -U
Centering ring with multifunction coating and integrated protection screen, DN 200 SO-K/-F	PM 016 222 -U	PM 016 222 -U
Centering ring with multifunction coating and integrated splinter shield, DN 200 ISO-K/F	PM 016 221 -U	PM 016 221 -U
DCU 002, Display Control Unit	PM 061 348 -T	PM 061 348 -T
HPU 001, Handheld Programming Unit	PM 051 510 -T	PM 051 510 -T
Accessories package for HPU 001/PC	PM 061 005 -T	PM 061 005 -T
Mains cable 230 V AC, CEE 7/7 to HAN 3A, 3 m	P 4564 309 HA	P 4564 309 HA
Mains cable 115 V AC, NEMA 5-15 to HAN 3A, 3 m	PM 061 187 -X	PM 061 187 -X
Mains cable 208 V AC, NEMA 6-15 to HAN 3A, 3 m	P 4564 309 HB	P 4564 309 HB
/enting valve, shielded, 24 V DC, G 1/8", for connection to TC 400/1200 and TM 700	PM Z01 291	PM Z01 291
TTV 001, dryer for venting turbopumps	PM Z00 121	PM Z00 121
TVV 001 fore-vacuum safety valve, 230 V AC	PM Z01 205	PM Z01 205
TVV 001 fore-vacuum safety valve, 115 V AC	PM Z01 206	PM Z01 206
Sealing gas valve, shielded, HiPace 400/700/800 P with TC 400 and HiPace 1200 - 2300 with TC 1200	PM Z01 313	PM Z01 313
Sealing gas throttle for HiPace 400/700/800 P version and HiPace 1200 - 2300	PM Z01 318	PM Z01 318
/ibration damper for HiPace 800/1200/1800, DN 200 ISO-K/F	PM 006 668 -X	
JSB converter to RS-485 interface	PM 061 207 -T	PM 061 207 -T
nterface cable, M12 m straight/M12 m straight, 3 m	PM 061 283 -T	PM 061 283 -T
nterface cable, M12 m straight/ M12 m angled 0.7 m	PM 061 791 -T	PM 061 791 -T
/-Connector M12 to RS-485	P 4723 010	P 4723 010
Remote mating plug, HD26-pole with bridges	PM 061 378 -X	PM 061 378 -X
Mains supply socket	PM 061 200 -T	PM 061 200 -T
RJ 45 interface cable on M12 for HiPace	PM 051 726 -T	PM 051 726 -T
Venting valve, 24 V DC, G 1/8" without cable	PM Z01 293	PM Z01 293
Power failure venting valve, shielded, 24 V DC, G 1/8" for connection to TC 400, TM 700 and TC 1200	PM Z01 331	PM Z01 331
	PM 016 787 -T	PM 016 787 -T
Banjo titting		
Banjo fitting Banjo fitting, small	PM 143 877 -T	PM 143 877 -T

Accessories

Designation	DN 200 ISO-K	DN 200 ISO-F
Push-in fitting for 6 mm hose, G 1/8"	PM 016 781 -T	PM 016 781 -T
Push-in fitting for 8 mm hose, G 1/8"	PM 016 782 -T	PM 016 782 -T
Hose nozzle for 9 mm hose, G 1/8"	PM 016 783 -T	PM 016 783 -T
Relay box, shielded, for backing pumps, 1-phase 7 A for TC 400/1200, TM 700 and TCP 350, M12	PM 071 284 -X	PM 071 284 -X
Relay box, shielded, for backing pumps, 1-phase 20 A for TC 400/1200, TM 700 and TCP 350, M12	PM 071 285 -X	PM 071 285 -X
HiPace - ACP connection cable	PM 071 142 -X	PM 071 142 -X
Y-connector, shielded, M12 for accessories	P 4723 013	P 4723 013
Sealing gas monitoring unit G 1/8"	PM 016 911 -U	

13 Technical data and dimensions

13.1 General

Basic principles for the Technical Data of Pfeiffer Vacuum Turbopumps:

Maximum values refer exclusively to the input as a single load.

- Recommendations of PNEUROP committee PN5
- ISO 21360; 2007: "Vacuum technology Standard methods for measuring vacuumpump performance - General description"
- ISO 5302; 2003: "Vacuum technology Turbomolecular pumps Measurement of performance characteristics"
- Ultimate pressure: using a test dome and a 48 hrs. period of baking out
- Gas throughput: at water cooling, cooling water temp. 25 °C; backing pump = rotary vane pump (120 m³/h)
- Power charactersitics: cooling water temperature 25 °C
- Cooling water consumption: at max. gas throughput, cooling water temp. 25 °C
- Integral leak rate: using a Helium concentration of 100 %, period 10 s
- Sound pressure level: Distance 1 m to the pump

Conversion table: pressure units

	mbar	bar	Pa	hPa	kPa	Torr mm Hg
mbar	1	1 · 10 ⁻³	100	1	0.1	0.75
bar	1000	1	1 · 10 ⁵	1000	100	750
Pa	0.01	1 · 10 ⁻⁵	1	0.01	1 · 10 ⁻³	7.5 · 10 ⁻³
hPa	1	1 · 10 ⁻³	100	1	0.1	0.75
kPa	10	0.01	1000	10	1	7.5
Torr mm Hg	1.33	1.33 · 10 ⁻³	133.32	1.33	0.133	1
		1	1 Pa = 1 N/m ²	1	1	1

Conversion table: gas throughput units

	mbar·l/s	Pa⋅m³/s	sccm	Torr-I/s	atm-cm ³ /s
mbar·l/s	1	0.1	59.2	0.75	0.987
Pa⋅m³/s	10	1	592	7.5	9.87
sccm	1.69 · 10 ⁻²	1.69 · 10 ⁻³	1	1.27 · 10 ⁻²	1.67 · 10 ⁻²
Torr·l/s	1.33	0.133	78.9	1	1.32
atm·cm ³ /s	1.01	0.101	59.8	0.76	1

13.2 HiPace 1800 / HiPace 1800 U

Parameter	HiPace [®] 1800 U	HiPace [®] 1800 U
Flange (in)	DN 200 ISO-K	DN 200 ISO-F
Flange (out)	DN 40 ISO-KF	DN 40 ISO-KF
Pumping speed for Ar	1370 l/s	1370 l/s
Pumping speed for H ₂	1700 l/s	1700 l/s
Pumping speed for He	1650 l/s	1650 l/s
Pumping speed for N ₂	1450 l/s	1450 l/s
Compression ratio for Ar	> 1 · 10 ⁸	> 1 · 10 ⁸
Compression ratio for H ₂	2 · 10 ⁴	2 · 10 ⁴
Compression ratio for He	3 · 10 ⁵	3 · 10 ⁵
Compression ratio for N ₂	> 1 · 10 ⁸	> 1 · 10 ⁸
Gas throughput at full rotational speed for Ar	16 hPa l/s	16 hPa l/s
Gas throughput at full rotational speed for He	20 hPa I/s	20 hPa I/s
Gas throughput at full rotational speed for H ₂	> 50 hPa l/s	> 50 hPa l/s
Gas throughput at full rotational speed for N ₂	28 hPa l/s	28 hPa I/s


Parameter	HiPace [®] 1800 U	HiPace [®] 1800 U
Fore-vacuum max. for Ar	2.4 hPa	2.4 hPa
Fore-vacuum max. for H ₂	0.55 hPa	0.55 hPa
Fore-vacuum max. for He	1 hPa	1 hPa
Fore-vacuum max. for N ₂	1.8 hPa	1.8 hPa
Run-up time	4 min	4 min
Ultimate pressure according to PNEUROP	< 1 · 10 ⁻⁷ hPa	< 1 · 10 ⁻⁷ hPa
Rotation speed ± 2 %	31500 min ⁻¹	31500 min ⁻¹
Rotation speed variable	50-100 %	50-100 %
Power characteristic line in gas mode 1, vertex A	690/31500 W/min ⁻¹	690/31500 W/min ⁻¹
Power characteristic line in gas mode 1, vertex B	750/25200 W/min ⁻¹	750/25200 W/min ⁻¹
Power characteristic line in gas mode 0, vertex C	517/31500 W/min ⁻¹	517/31500 W/min ⁻¹
Power characteristic line in gas mode 0, vertex D	682/25200 W/min ⁻¹	682/25200 W/min ⁻¹
Sound pressure level	≤ 50 dB (A)	≤ 50 dB (A)
Relative humidity of air	5-85 %	5-85 %
Protection category	IP54	IP54
Connection pressure max. for venting/sealing gas	1500 hPa	1500 hPa
valve		
Integral leak rate	< 1 · 10 ⁻⁸ Pa m ³ /s	< 1 · 10 ⁻⁸ Pa m ³ /s
Power consumption max.	1350 VA	1350 VA
Mains requirement: frequency (range)	50/60 Hz	50/60 Hz
Mains requirement: voltage (range)	100-120/200-240 V AC	100-120/200-240 V AC
Current consumption max.	10 A	10 A
Mounting orientation	Standard (0°-90°)	Standard (0°-90°)
Venting connection	G 1/8"	G 1/8"
Weight	37 kg	37,8 kg
Cooling method, standard	Water	Water
Cooling water temperature	15-35 °C	15-35 °C
Cooling water consumption	100 l/h	100 l/h
Permissible magnetic field max.	7 mT	7 mT
Interfaces	RS-485	RS-485

13.3 HiPace 1800 C / HiPace 1800 U C

Parameter	HiPace® 1800 C U C	HiPace® 1800 C U C
Flange (in)	DN 200 ISO-K	DN 200 ISO-F
Flange (out)	DN 40 ISO-KF	DN 40 ISO-KF
Pumping speed for Ar	1370 l/s	1370 l/s
Pumping speed for H ₂	1700 l/s	1700 l/s
Pumping speed for He	1650 l/s	1650 l/s
Pumping speed for N ₂	1450 l/s	1450 l/s
Compression ratio for Ar	> 1 · 10 ⁸	> 1 · 10 ⁸
Compression ratio for CF ₄	> 1 · 10 ⁸	> 1 · 10 ⁸
Compression ratio for H ₂	2 · 10 ⁴	2 · 10 ⁴
Compression ratio for He	3 · 10 ⁵	3 · 10 ⁵
Compression ratio for N ₂	> 1 · 10 ⁸	> 1 · 10 ⁸
Gas throughput at full rotational speed for Ar	16 hPa l/s	16 hPa l/s
Gas throughput at full rotational speed for CF ₄	14 hPa l/s	14 hPa l/s
Gas throughput at full rotational speed for He	20 hPa l/s	20 hPa l/s
Gas throughput at full rotational speed for H ₂	> 50 hPa l/s	> 50 hPa l/s
Gas throughput at full rotational speed for N ₂	28 hPa l/s	28 hPa I/s
Fore-vacuum max. for Ar	2.4 hPa	2.4 hPa
Fore-vacuum max. for H ₂	0.55 hPa	0.55 hPa
Fore-vacuum max. for He	1 hPa	1 hPa
Fore-vacuum max. for N ₂	1.8 hPa	1.8 hPa
Run-up time	4 min	4 min
Ultimate pressure according to PNEUROP	< 1 · 10 ⁻⁷ hPa	< 1 · 10 ⁻⁷ hPa
Rotation speed ± 2 %	31500 min ⁻¹	31500 min ⁻¹
Rotation speed variable	50-100 %	50-100 %
Power characteristic line in gas mode 1, vertex A	690/31500 W/min ⁻¹	690/31500 W/min ⁻¹

Parameter	HiPace [®] 1800 C U C	HiPace [®] 1800 C U C	
Power characteristic line in gas mode 1, vertex B	750/25200 W/min ⁻¹	750/25200 W/min ⁻¹	
Power characteristic line in gas mode 0, vertex C	517/31500 W/min ⁻¹	517/31500 W/min ⁻¹	
Power characteristic line in gas mode 0, vertex D	682/25200 W/min ⁻¹	682/25200 W/min ⁻¹	
Sound pressure level	≤ 50 dB (A)	≤ 50 dB (A)	
Relative humidity of air	5-85 %	5-85 %	
Protection category	IP54	IP54	
Connection pressure max. for venting/sealing gas valve	1500 hPa	1500 hPa	
Integral leak rate	< 1 · 10 ⁻⁸ Pa m ³ /s	< 1 · 10 ⁻⁸ Pa m ³ /s	
Power consumption max.	1350 VA	1350 VA	
Mains requirement: frequency (range)	50-60 Hz	50/60 Hz	
Mains requirement: voltage (range)	100-120/200-240 V AC	100-120/200-240 V AC	
Current consumption max.	10 A	10 A	
Mounting orientation	Standard (0°-90°)	Standard (0°-90°)	
Venting connection	G 1/8"	G 1/8"	
Weight	37 kg	37,8 kg	
Cooling method, standard	Water	Water	
Cooling water temperature	15-35 °C	15-35 °C	
Cooling water consumption	100 l/h	100 l/h	
Permissible magnetic field max.	7 mT	7 mT	
Interfaces	RS-485	RS-485	

13.4 Dimensions







Fig. 20: HiPace 1800, DN 200 ISO-K






Fig. 21: HiPace 1800, DN 200 ISO-F




Fig. 22: HiPace 1800 U, DN 200 ISO-K




Fig. 23: HiPace 1800 U, DN 200 ISO-F



We hereby declare that the product cited below satisfies all relevant provisions according to the following **EC directives**:

• Machinery 2006/42/EC (Annex II, no. 1 A)

The agent responsible for compiling the technical documentation is Mr. Helmut Bernhardt, Pfeiffer Vacuum GmbH, Berliner Straße 43, 35614 Aßlar.

HiPace 1800

Harmonised standards and national standards and specifications which have been applied:

DIN EN ISO 12100 : 2011-03 DIN EN 1012-2 : 2011 DIN EN 61000-3-2 : 2014 DIN EN 61000-3-3 : 2013 DIN EN 61010-1 : 2010 DIN EN 61326-1 : 2013 DIN EN 62061 : 2013

Signature:

Pfeiffer Vacuum GmbH Berliner Straße 43 35614 Asslar Germany

(Dr. Ulrich von Hülsen) Managing Director

Melmho. Hitch

2017-04-07



VACUUM SOLUTIONS FROM A SINGLE SOURCE

Pfeiffer Vacuum stands for innovative and custom vacuum solutions worldwide, technological perfection, competent advice and reliable service.

COMPLETE RANGE OF PRODUCTS

From a single component to complex systems:

We are the only supplier of vacuum technology that provides a complete product portfolio.

COMPETENCE IN THEORY AND PRACTICE

Benefit from our know-how and our portfolio of training opportunities!
We support you with your plant layout and provide first-class on-site service worldwide.

Are you looking for a perfect vacuum solution? Please contact us:

Pfeiffer Vacuum GmbH Headquarters • Germany T +49 6441 802-0 info@pfeiffer-vacuum.de

www.pfeiffer-vacuum.com

